

QUALITY CERTIFICATE

Factory Production Control (FPC)

This Quality Certificate is to guarantee, that the product listed below has been designed, manufactured and quality tested by Konvekta AG in Switzerland, according to the internal Konvekta quality standards.

These standards are in accordance with the rules set out by **EN- 2006/42/EG**.

Factory:	Konvekta AG Letzistr.23 CH-9015 St. Gallen SWITZERLAND
Product:	High-Performance-Heat-Exchanger
Serial number:	86120300-101 1/2
Year built:	2013
Materials:	Tubes: Copper DIN 1754 CU-DHP Fins: Aluminium EN AW-1050A, H19 Header: Steel DIN 2395
Pressure test:	Minimum 3.2MPa cold water for a minimum period of 2 days Successfully passed: 9.10.13 , Operator: kueP
Optical test:	Successfully passed: 9.10.13 , Operator: maks

The above listed product is covered with a **2 year manufacturer warranty** against mechanical defects. The warranty is void, if improper handling or installation has caused damage to the unit, or if unauthorized personnel has done any repairs or unauthorized modifications to the unit.



Quality Control Department
October 9, 2013

Peter Kuenzle, QA-Officer